

TR12323498

24.11.2023



EUROLAB LABORATUVAR A.Ş.

Report No/ Rapor No : 2023112431
Applicant/Deney Sahibi : ORTAÇLAR KABLO BAĞLANTI ELEMANLARI
Contact Person / Yetkili : Hasan KILINÇ
Contact Telephone / Telefon: -
Contact e-mail / E-Posta: -
Sample Accepted on / Numune Tarihi: 09.11.2023
Report Date / Rapor Tarihi : 24.11.2023
Total number of pages/Rapor Sayfa : 6 Page

Sample ID : **PA Non Metal Cable Glands – Conduit Fittings – Conduit Glands & Accessories**

| | TEST/ INSPECTION | DIRECTIVE | METHOD | RESULT | |
|---|---|--|---------------------------|------------|------------|
| * | Railway applications — Fire protection on railway vehicles Part 2: Requirements for fire behaviour of materials and components | Construction Product Inspections EU 305/2011 89/106/EEC | EN 45545-2 R22-R23 | R22 | R23 |
| | | | | HL2 | HL3 |

NOTE: This test/inspection result replaces the conformity assessment, can be presented to official institutions, and used in products and brochures.



Seal

Customer Representative

Merve Nur KIRVELİ

Laboratory Manager

Merve ÖZLÜ

Test/inspection results, methods and other information about the sample shown in the relevant pages of this Report are based on the information specified in accordance with "Test/inspection Request Form (PR03-F01) conveyed to us from the Applicant. Test/inspection results are valid for the sample as identified above. Sample may not represent the lot which it belongs. This Report does not replace a Product Certificate. Full report or any part of it may not be reproduced or used for any other purpose without the written permission of EUROLAB Laboratory. Sampling has not been done by us. Unsigned and unsealed Reports are invalid. Analysis as indicated with "*" are in the Scope of our Accreditation Certificate issued from UAF according to TS EN ISO/IEC 17020, 17025, Analysis as indicated with "**" are performed at the external laboratories using accredited test/inspection methods according to EN ISO/IEC 17020, 17025 from UAF. Possible extra notes may add with starting N1 to related pages. Tested and remaining samples will be kept in specified terms & conditions at test/inspection request and/or proposal form. Physically, chemically and microbiologically decomposed samples are discarded regardless of the storage period. Applicant can not claim any right in this regard. Results are shown in this Report do not include Measurement Uncertainty values. Measurement Uncertainty values are not taken in consideration during Pass/Fail assessment the of test/inspection results shown in this Report. Evaluation of the test/inspection results using Measurement Uncertainty values is the responsibility of the Applicant. An inspection body shall issue an inspection certificate that does not include the inspection results only when the inspection body can also produce an inspection report containing the inspection results, and when both the inspection certificate and inspection report are traceable to each other..

PR33-F01/08.10.2015/Rev.:17.01.2017-R01

Page 1 / 4

Address: Merkez Mh, Dr Sadık Ahmet Cd, No 38/44, Bağcılar, İstanbul, Türkiye
Contact: www.laboratuvar.com e-mail: info@laboratuvar.com